



EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

September 19, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7018 0680 0000 1017 5291

Ms. Christine Kaplan, Manager
City Yachts and Gashouse Cove Marina
10 Marina Boulevard
San Francisco, California 94123
chrissy@citysf.com

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS
LOCATED AT GASHOUSE COVE MARINA, INC. 10 MARINA BOULEVARD,
SAN FRANCISCO**

Dear Ms. Kaplan:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST(s) at your facility on September 13, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Perform Designated Operator (DO) Inspections – The June 2018 DO inspection was not performed.	All	June 1, 2018	June 30, 2018	23 CCR 2715(c)
2	Failure to Maintain Tank Information – In CERS, under fill pipe construction, fill components installed, containment sump lists “yes”; however, it should list “no.”	All	September 13, 2018	Ongoing	H&SC 25286(a); 23 CCR 2711(a)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and San Francisco City & County Public Health Department within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

1001 I Street, Sacramento, CA 95814 | Mailing Address: P.O. Box 100, Sacramento, CA 95812-0100 | www.waterboards.ca.gov

Please send all compliance documentation to the following:

State Water Board

Mr. Douglas McDevitt
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
douglas.mcdevitt@waterboards.ca.gov

Local CUPA

Mr. Thomas Chan
Environmental Health Inspector
San Francisco City & County
Public Health Department
1390 Market Street, Room 210
San Francisco, California 94102
thomas.chan@sfdph.org

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: *(via email only)*

Mr. Thomas Chan
Environmental Health Inspector
San Francisco City & County
Public Health Department
thomas.chan@sfdph.org

Mr. Billy Puk
Environmental Health Inspector
San Francisco City & County
Public Health Department
billy.puk@sfdph.org

Ms. Paula Stewart
Program Manager
San Francisco City & County
Public Health Department
paula.stewart@sfdph.org